# **Utah Department of Environmental Quality Division of Drinking Water**

# Public Water System Inventory Report

Run Date: 08/04/2011 12:07 pm

PWS ID: UTAH13014 Name: GLEN CANYON NRA-BULLFROG

Legal Contact NPS - GLEN CANYON NRA Rating: Approved

> STAN AUSTIN Rating Date: 06/24/1996

Address: PO BOX 1507 Activity Status: Active

PAGE, AZ 86040

Phone Number: 435-608-6332

City Served (Area):

County: KANE COUNTY Gal/Day Gal/Min

System Type: Community Last Inv Update: 08/16/2010 Avg Daily Prod: Activity Status Cd: Active Last Snty Srv Dt: 08/20/2008 Total Dsgn Cap: Population: 350 Surveyor: YING YING L MACAUL **Total Emerg Cap:** 

Oper Period: 1/1 to 12/31

**Contacts** 

Contact			Phone Numbers						
Type	Name	Title Office		Emergency	Email Address				
AC	AUSTIN, STAN	SUPERINTEND	435-608-6254		_				

### Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connection	s
Residential	Metered	0	117	
Commercial	Unknown	0	9	
			126	— Total Svc Connection:

## Storage

Total Storage: 1,000,000 GAI Number of Units: 2 Adequate Capacity: NO

				Constr	Overflow	Activity	
No.	Name	Type	Effective Volume	Matri	Elev	Status	Press'd
ST001	EAST RESERVOIR	Ground	500,000 GAL	Steel		Α	NO
ST002	WEST RESERVOIR	Ground	500,000 GAL	Steel		Α	NO

## Treatment Plants

No.	Plant Name	Approved Design Capacity (gal/day)	Activity Status	Treatment Process
TP001	WELL #2 CHLORINATOR		Α	

# **Distribution System**

Pump Type	Total Dy	n Head	Pressure	Cross	Auhority
	ft H2O	P.S.I.	Adequate	Connection	Statement
			No		

#### Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	#1 WELL	Active	WL	6	180 GPM	180 GPM	Yes	GW	Permanent	1/1 to 12/31	
WS002	#2 WELL	Active	WL	8	200 GPM	328 GPM	Yes	GW	Permanent	1/1 to 12/31	
WS003	#3 WELL	Active	WL	16	200 GPM	296 GPM	Yes	GW	Permanent	1/1 to 12/31	

<sup>\*</sup>Reports measured flow for wells, approved design capacity for all other sources.